Certificate of Compliance

Certificate Number:
UL-CA-2436405-0

Report Reference:
E484838-20241219

Issue Date:
2025-01-07

Issued to:

HONEYWELL CO LTD
5F SangAm IT Tower
434 World Cup Buk-ro Mapo-gu Seoul, Seoul 03922
Republic of Korea

This certificate confirms that representative samples of:
QUZW7 - Process Control Equipment for Use in Hazardous Locations Certified for Canada

See Addendum Page for Product Designation(s).

Have been evaluated by UL in accordance with the Standard(s) indicated on this Certificate.

CSA C22.2 No. 30, Edition 4, Issued 2020-04-01, CSA C22.2 NO. 25, 4th Ed., Issue Date: 2017-07-01, CSA C22.2 NO. 61010-1, 3rd Ed., Issue Date: 2012-05-11, Revision Date: 2018-11-01, CSA C22.2 No. 60079-0, Edition 4, Issued 2019-02-01, CSA C22.2 NO. 60079-11:14, 2nd Ed., Issue Date: 2014-02-01

Additional Information:
See UL Product iQ® at https://iq.ulprospector.com for additional information.

This Certificate of Compliance indicates that representative samples of the product described in the certification report have met the requirements for UL certification. It does not provide authorization to apply the UL Mark. Only the Authorization Page that references the Follow-Up Services Procedure for ongoing surveillance provides authorization to apply the UL Mark.

Only those products bearing the UL Mark should be considered as being UL Certified and covered under UL's Follow-Up Services.

Look for the UL Certification Mark on the product.

David Piecuch
UL Mark Certification Program Owner

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact UL Solutions Customer Service at https://www.ul.com/contact-us.

© 2025 UL LLC. All rights reserved.

CERTIFICATE OF COMPLIANCE

Certificate number UL-CA-2436405-0
Report reference E484838-20241219
Date 2025-01-07

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

Model	Product Description
OmniPoint, Local HART Interface	Process Control Equipment for HazLoc

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact UL Solutions Customer Service at https://www.ul.com/contact-us.

© 2025 UL LLC. All rights reserved.